

Map ID
Direction
Distance
Elevation

MAP FINDINGS

Site

Database(s)

EDR ID Number
EPA ID Number

HT1103
ENE
> 1
1.448 mi.
7645 ft.

2507 EAST 15TH ST/BKLYN
2507 EAST 15TH STREET
NEW YORK CITY, NY

NY Spills S102140975
N/A

Site 1 of 2 in cluster HT

Relative:
Higher

Actual:
21 ft.

SPILLS:

Name: 2507 EAST 15TH ST/BKLYN
Address: 2507 EAST 15TH STREET
City,State,Zip: NEW YORK CITY, NY
Spill Number/Closed Date: 9102334 / 1991-09-19
Facility ID: 9102334
Facility Type: ER
DER Facility ID: 229191
Site ID: 282313
DEC Region: 2
Spill Cause: Equipment Failure
Spill Class: Not reported
SWIS: 2401
Spill Date: 1991-05-29
Investigator: SJMILLER
Referred To: Not reported
Reported to Dept: 1991-05-29
CID: Not reported
Water Affected: Not reported
Spill Source: Institutional, Educational, Gov., Other
Spill Notifier: Responsible Party
Cleanup Ceased: 1991-09-19
Cleanup Meets Std: True
Last Inspection: Not reported
Recommended Penalty: False
UST Trust: False
Remediation Phase: 0
Date Entered In Computer: 1991-06-03
Spill Record Last Update: 1992-03-17
Spiller Name: Not reported
Spiller Company: NYCTA
Spiller Address: 370 JAY STREET

Spiller Company: 001

Contact Name: Not reported

DEC Memo: "Prior to Sept, 2004 data translation this spill Lead_DEC Field was
MILLER 10/10/95: This is additional information about material
spilled from the translation of the old spill file: 100PPM."

Remarks: "TRANSFORMER BLEW, SPILL CONTAINED ON CONCRETE BY SORBENTS, CONTRACTOR
(ONISON) DUE ON SCENE FOR CLEAN UP."

All Materials:

Site ID: 282313
Operable Unit ID: 956201
Operable Unit: 01
Material ID: 424858
Material Code: 0017A
Material Name: PCB oil
Case No.: Not reported
Material FA: Petroleum
Quantity: 200.00
Units: G
Recovered: .00
Oxygenate: Not reported